

CERTIFICATE

Certificate holder	Evopipes SIA Langervaldes Street 2 a 3002 Jelgava LATVIA
Production facility	Jelgava
Product	Pressure pipes made from Polyethylene (PE) for alternative installation techniques - PE 100-RC
Classification	EG 926.3, Outer diameter 250 mm up to 630 mm
Type, Model	ULTRASTRESS
Remarks to the type	PAS 1075 Type 1 - TW Basis EN 12201-2
Testing basis	PAS 1075:2009-04 Certification Scheme Plastic Piping Systems (Pressure Pipes and Fittings) (2017-05)

Mark of conformity

Registration No. P1R0565

Valid until 2024-10-31

Right of use

This certificate entitles the holder to use the mark of conformity shown above in conjunction with the specified registration number.
See annex for further information.

2019-10-15
Dipl.-Wi.-Ing. (FH) Sören Scholz
Head of Certification Body

S. Scholz



ANNEX

Page 1 of 1

Certificate

P1R0565 dated 2019-10-15

Technical DataPAS 1075 Type 1 - TW
Basis EN 12201-2

Outer diameter 250 mm up to 630 mm, SDR 11 and SDR 17

Maximum wall thickness: 44,7 mm

Material: PE 100-RC

Material type: see production facility related material list

Colour: black with blue stripes

Operating over pressure burstlining: see Certification Scheme Plastic piping systems
(Pressure pipes and fittings)(2017-05) Annex O 14**Testing laboratory/
Inspection body**Hessel Ingenieurtechnik GmbH
Am Münsterwald 3
52159 Roetgen
GERMANY**Test report(s)**R19 03 3451-E1-E2_PLT+ dated 2019-10-09,
R19 03 3451-E3-E4_PLT_interim report dated 2019-10-07,
R19 03 3451-A_ACT dated 2019-10-07,
R19 03 3451-A1-A2-A3_PLT+ dated 2019-09-13,
R19 03 3451-A7-A8-A9_Penetration_interim report dated 2019-10-08,
R19 03 3451-C_ACT dated 2019-10-07