

CERTIFICATE

Certificate holder	Evopipes SIA Langervaldes Street 2 a 3002 Jelgava LATVIA
Production facility	Jelgava
Product	Pressure pipes made from Polyethylene (PE) for alternative installation techniques - PE 100-RC
Classification	EG 926.1, Outer diameter 32 mm up to 63 mm
Type, Model	ULTRASTRESS
Remarks to the type	PAS 1075 Type 1 - G Basis EN 1555-2
Testing basis	PAS 1075:2009-04 Certification Scheme Plastic Piping Systems (Pressure Pipes and Fittings) (2017-05)

Mark of conformity**Registration No.** P1R0555**Valid until** 2024-10-31**Right of use**

This certificate entitles the holder to use the mark of conformity shown above in conjunction with the specified registration number.
See annex for further information.

2019-10-15

S. S. J.
Dipl.-Wi.-Ing. (FH) Sören Scholz
Head of Certification Body



ANNEX

Certificate

P1R0555 dated 2019-10-15

Technical Data

PAS 1075 Type 1 - G
Basis EN 12201-2

Outer diameter 32 mm up to 63 mm, SDR 11 and SDR 17

Minimum wall thickness: 3,0 mm

Material: PE 100-RC

Material type: see production facility related material list

Colour: black with orange stripes

Operating over pressure burstlining: see Certification Scheme Plastic piping systems (Pressure pipes and fittings)(2017-05) Annex 0 14

**Testing laboratory/
Inspection body**

Hessel Ingenieurtechnik GmbH
Am Münsterwald 3
52159 Roetgen
GERMANY

Test report(s)

R19 03 3451-E1-E2_PLT+ dated 2019-10-09,
R19 03 3451-E3-E4_PLT_interim report dated 2019-10-07,
R19 03 3451-A_ACT dated 2019-10-07,
R19 03 3451-A1-A2-A3_PLT+ dated 2019-09-13,
R19 03 3451-A7-A8-A9_Penetration_interim report dated 2019-10-08,
R19 03 3451-C_ACT dated 2019-10-07

