

CERTIFICATE

Certificate holder	Evopipes SIA Langervaldes Street 2 a 3002 Jelgava LATVIA
Production facility	Jelgava
Product	Pressure pipes made from Polyethylene (PE) for alternative installation techniques - PE 100-RC
Classification	EG 926.2, Outer diameter 75 mm up to 225 mm
Type, Model	ULTRASTRESS VISIO
Remarks to the type	PAS 1075 Type 2 2L - AW Basis EN 12201-2
Testing basis	PAS 1075:2009-04 Certification Scheme Plastic Piping Systems (Pressure Pipes and Fittings) (2017-05)

Mark of conformity**Registration No.** P1R0563**Valid until** 2024-10-31**Right of use**

This certificate entitles the holder to use the mark of conformity shown above in conjunction with the specified registration number.
See annex for further information.

2019-10-15

S. Scholz
Dipl.-Wi.-Ing. (FH) Sören Scholz
Head of Certification Body



ANNEX

Page 1 of 1

Certificate

P1R0563 dated 2019-10-15

Technical DataPAS 1075 Type 2 2L - AW
Basis EN 12201-2

Outer diameter 75 mm up to 225 mm, SDR 11 and SDR 17

Material: PE 100-RC

Material type: see production facility related material list

Colour outer layer: brown

Colour inner layer: black

Operating over pressure burstlining: see Certification Scheme Plastic piping systems
(Pressure pipes and fittings)(2017-05) Annex 0 14**Testing laboratory/
Inspection body**Hessel Ingenieurtechnik GmbH
Am Münsterwald 3
52159 Roetgen
GERMANY**Test report(s)**R19 03 3451-E1-E2_PLT+ dated 2019-10-09,
R19 03 3451-E3-E4_PLT_interim report dated 2019-10-07,
R19 03 3451-A_ACT dated 2019-10-07,
R19 03 3451-A1-A2-A3_PLT+ dated 2019-09-13,
R19 03 3451-A7-A8-A9_Penetration_interim report dated 2019-10-08,
R19 03 3451-C_ACT dated 2019-10-07