

SIA "Bureau Veritas Latvia" Duntes streeta 17a, Riga, LV-1005, Latvia

CERTIFICATE OF CONFORMITY

No. 25/063

awarded to

SIA "EVOPIPES"

Langervaldes street 2a, Jelgava, LV-3002, Latvia

Bureau Veritas Latvia certifies that the above mentioned Company has been manufacturing product: Electrical wiring conduits for civil, public and industrial building construction

EVOEL FL-0H – SMART EVOEL FM-0H – SMART EVOEL FMs-0H – SMART EVOEL FMs – UV - 0H - SMART EVOEL FHs – UV - 0H – SMART EVOCAB FLEX FR UV 0H

(characteristics are detailed in the attached annex)

according to standards

LVS EN 61386-1:2018 "Conduit systems for cable management - Part 1: General requirements" and

LVS EN IEC 61386-22:2021; LVS EN IEC 61386-22:2021/A11:2021 "Conduit systems for cable management - Part 22: Particular requirements - Pliable conduit systems"

and Bureau Veritas Latvia procedure PSP/22 requirements
under system "Factory and Factory Production Control initial evaluation and surveillance, that includes
evaluation of Factory and Factory Production Control".

This certificate was first issued on 21/10/2016 and will remain valid until 20/10/2028 as long as neither the standard, the construction product, the testing methods nor the manufacturing conditions in the plant are modified significantly.

On conditions to satisfy continuously to quality requirements and submitted to annual re-evaluation by BV Auditors qualified for this.

To check the validity date of this certificate, please call +371 67323246.

Further clarification regarding the scope of this certificate and the applicability of the system requirements may be obtained by consulting the organisation.

Annex to certificate on 1 (one) page is integral part of this certificate.

Certificate issued:

Riga, 21/10/2025

Version:

1//

Certificate validity:

20/10/2028

10/2020

SIA "Bureau Veritas Latvia" Member of the board Iveta Lazdiņa

SIA Bureau Veritas Latvia Product Certification Body Certificate F_S/Page. 1 of 2 – Vers.1, 02.10.2019.



ANNEX TO CERTIFICATE: No. 25/063

Date: 21/10/2025

Product	Nominal size range, mm	Nominal (mechanical) resistance to compression class (N/5cm)	
EVOEL FL-0H – SMART Corrugated pliable conduits for electrical installations from halogen-free, self-extinguishing plastic	DN 16 - 50	320	
EVOEL FM-0H SMART Corrugated pliable conduits for electrical installations from halogen-free, self-extinguishing plastic	DN 16 - 50	750	
EVOEL FMs - 0H - SMART Corrugated pliable conduits for electrical installations with sheathing layer from halogen-free, self-extinguishing plastic	DN 16 - 50	750	
EVOEL FMs – UV - 0H - SMART Corrugated pliable conduits for electrical installations from halogen-free, self-extinguishing plastic with UV-resistant sheathing layer	DN 16 - 50	750	
EVOEL FHs – UV - 0H - SMART Corrugated pliable conduits for electrical installations from halogen-free, self-extinguishing plastic with UV-resistant sheathing layer	DN 16 - 50	1250	

Product	Nominal size range, mm	Nominal (mechanical) compression strength class, N	Impact resistance class
EVOCAB FLEX FR UV 0H Corrugated pliable double-wall conduits for electrical installations with smooth internal and profiled external surface made from halogen-free, flame-resistant, UV-resistant plastic, with pre-installed pulling wire	DN 75 - 160	750	N

SIA "Bureau Veritas Latvia" Member of the board

Duntes street17a, Riga, LV-1005

"BUREAU ENTAS Iveta Lazdiņa

SIA Bureau Veritas Latvia Product Certification Body Certificate F_S/22 Page, 2 of 2 – Vers.1, 02.10.2019.