

CERTIFICATE

Certificate holder	Evopipes SIA Langervaldes Street 2 a 3002 Jelgava LATVIA
Production facility	Jelgava
Product	Pressure pipes made from Polyethylene (PE) for alternative installation techniques - PE 100-RC
Classification	EG 926.2, Outer diameter 75 mm up to 225 mm
Type, Model	ULTRASTRESS PROTECT GAS
Remarks to the type	PAS 1075 Type 3 - G Basis EN 1555-2
Testing basis	PAS 1075:2009-04 Certification Scheme Plastic Piping Systems (Pressure Pipes and Fittings) (2017-05)

Mark of conformity**Registration No.** P1R0576**Valid until** 2024-10-31**Right of use** This certificate entitles the holder to use the mark of conformity shown above in conjunction with the specified registration number.
See annex for further information.

2019-12-13

Dipl.-Wi.-Ing. (FH) Sören Scholz
Head of Certification Body

A handwritten signature in blue ink, appearing to be 'S. S.', is written over a horizontal line.



ANNEX

Page 1 of 1

Certificate

P1R0576 dated 2019-12-13

Technical DataPAS 1075 Type 3 - G
Basis EN 1555-2

Outer diameter 75 mm up to 225 mm, SDR 11 and SDR 17

Material: PE 100-RC

Material type: see production facility related material list

Colour core pipe: black

Colour protective layer: orange

**Testing laboratory/
Inspection body**Hessel Ingenieurtechnik GmbH
Am Münsterwald 3
52159 Roetgen
GERMANY**Test report(s)**R19 03 3451-F_ST dated 2019-10-09
R19 03 3451-E3-E4_PLT_interim report dated 2019-10-07,
R19 03 3451-B4-B5-B6_Penetration_interim report dated 2019-10-08,
R19 03 3451-B7_ST dated 2019-10-01,
R19 03 3451-D_ACT dated 2019-10-07,
R19 03 3451-D4_ST dated 2019-10-02