



**BUREAU
VERITAS**

SIA „Bureau Veritas Latvia”
Duntes streeta 17a, Riga, LV-1005, Latvia

CERTIFICATE OF CONFORMITY

No. 19/072

awarded to

SIA ”EVOPIPES”

Langervaldes street 2a, Jelgava, LV-3002, Latvia

Bureau Veritas Latvia certifies that the above mentioned Company has been manufacturing product:
Electrical wiring conduits for civil, public and industrial building construction

EVOEL FL-0H – SMART

EVOEL FM-0H – SMART

EVOEL FM_s-0H – SMART

EVOEL FM_s – UV - 0H - SMART

EVOEL FH_s – UV - 0H – SMART

EVO CAB FLEX FR UV 0H

(characteristics are detailed in the attached annex)

according to standards

LVS EN 61386-1:2018 “Conduit systems for cable management - Part 1: General requirements”
and

LVS EN IEC 61386-22:2021; LVS EN IEC 61386-22:2021/A11:2021 “Conduit systems for cable management - Part 22: Particular requirements - Pliable conduit systems”

and Bureau Veritas Latvia procedure PSP/22 requirements

under system “Factory and Factory Production Control initial evaluation and surveillance, that includes evaluation of Factory and Factory Production Control”.

This certificate was first issued on **21/10/2016** and will remain valid until **20/10/2022** as long as neither the standard, the construction product, the testing methods nor the manufacturing conditions in the plant are modified significantly.

On conditions to satisfy continuously to quality requirements and submitted to annual re-evaluation by BV Auditors qualified for this.

To check the validity date of this certificate, please call +371 67323246.

Further clarification regarding the scope of this certificate and the applicability of the system requirements may be obtained by consulting the organisation.

Annex to certificate on 1 (one) page is integral part of this certificate.

Certificate issued: Riga, 14/05/2022

Certificate validity: 20/10/2022

SIA „Bureau Veritas Latvia”
Member of the board



Iveta Lazdiņa



**BUREAU
VERITAS**

ANNEX TO CERTIFICATE: No. 19/072

Date: 14/05/2022

Product	Nominal size range, mm	Nominal (mechanical) resistance to compression class (N/5cm)
EVOEL FL-0H – SMART Corrugated pliable conduits for electrical installations from halogen-free, self-extinguishing plastic	DN 16 - 50	320
EVOEL FM-0H – SMART Corrugated pliable conduits for electrical installations from halogen-free, self-extinguishing plastic	DN 16 - 50	750
EVOEL FM_s - 0H - SMART Corrugated pliable conduits for electrical installations with sheathing layer from halogen-free, self-extinguishing plastic	DN 16 - 50	750
EVOEL FM_s – UV - 0H - SMART Corrugated pliable conduits for electrical installations from halogen-free, self-extinguishing plastic with UV-resistant sheathing layer	DN 16 - 50	750
EVOEL FH_s – UV - 0H - SMART Corrugated pliable conduits for electrical installations from halogen-free, self-extinguishing plastic with UV-resistant sheathing layer	DN 16 - 50	1250

Product	Nominal size range, mm	Nominal (mechanical) compression strength class, N	Impact resistance class
EVOCAB FLEX FR UV 0H Corrugated pliable double-wall conduits for electrical installations with smooth internal and profiled external surface made from halogen-free, flame-resistant, UV-resistant plastic, with pre-installed pulling wire	DN 75 - 160	750	N

SIA „Bureau Veritas Latvia”
Member of the board

Duntes street 17a, Riga, LV-1005



Iveta Lazdiņa