


CERTIFICATE

Certificate holder	Evopipes SIA Langervaldes Street 2 a 3002 Jelgava LATVIA
Production facility	Jelgava
Product	Pressure pipes made from Polyethylene (PE) for alternative installation techniques - PE 100-RC
Classification	EG 926.1, Outer diameter 32 mm up to 63 mm
Type, Model	ULTRASTRESS PROTECT GAS
Remarks to the type	PAS 1075 Type 3 - G Basis EN 1555-2
Testing basis	PAS 1075:2009-04 Certification Scheme Plastic Piping Systems (Pressure Pipes and Fittings) (2017-05)
Mark of conformity	
Registration No.	P1R0573
Valid until	2024-11-30
Right of use	This certificate entitles the holder to use the mark of conformity shown above in conjunction with the specified registration number. See annex for further information.

2019-12-13


Dipl.-Wi.-Ing. (FH) Sören Scholz
Head of Certification Body



ANNEX

Page 1 of 1

Certificate

P1R0573 dated 2019-12-13

Technical Data

PAS 1075 Type 3 - G
Basis EN 1555-2

Outer diameter 32 mm up to 63 mm, SDR 11 and SDR 17

Minimum wall thickness: 3,0 mm

Material: PE 100-RC

Material type: see production facility related material list

Colour core pipe: black
Colour protective layer: orange

**Testing laboratory/
Inspection body**

Hessel Ingenieurtechnik GmbH
Am Münsterwald 3
52159 Roetgen
GERMANY

Test report(s)

R19 03 3451-F_ST dated 2019-10-09
R19 03 3451-B_ACT dated 2019-10-07
R19 03 3451-B4-B5-B6_Penetration_interim report dated 2019-10-08,
R19 03 3451-B7_ST dated 2019-10-01,
R19 03 3451-D_ACT dated 2019-10-07,
R19 03 3451-D4_ST dated 2019-10-02,
R19 03 3451-F_ST dated 2019-10-09,
R19 03 3451-F4-F5 PLT+ dated 2019-11-06
R19 03 3451-F6-F7 PLT interim report dated 2019-11-06

