



**BUREAU
VERITAS**

SIA „Bureau Veritas Latvia”
Duntes streeta 17a, Riga, LV-1005, Latvia

CERTIFICATE OF CONFORMITY

No. 22/064

awarded to

SIA ”EVOPIPES”

Langervaldes street 2a, Jelgava, LV-3002, Latvia

Bureau Veritas Latvia certifies that the above mentioned Company has been manufacturing product: Conduit systems buried underground for protection and management of insulated conductors and/or cables in electrical installations or in communication systems. Smooth rigid 3-layer conduits with smooth internal and external surface from polypropylene (PP), with water tight joint. Nominal sizes **DN 110 mm** and **DN/OD 160 mm** with nominal compression strength class **750 (N)** and impact resistance class **N**

RIGID MULTI PP

according to standard

LVS EN 61386-1:2018 “Conduit systems for cable management - Part 1: General requirements”
and

LVS EN 61386-24:2011 “Conduit systems for cable management - Part 24: Particular requirements - Conduit systems buried underground (IEC 61386-24:2004)”

and Bureau Veritas Latvia procedure PSP/22 requirements under system “Factory and Factory Production Control initial evaluation and surveillance, that includes evaluation of Factory and Factory Production Control”.

This certificate was first issued on **11/10/2018** and will remain valid until **20/10/2025** as long as neither the standard, the construction product, the testing methods nor the manufacturing conditions in the plant are modified significantly.

On conditions to satisfy continuously to quality requirements and submitted to annual re-evaluation by BV Auditors qualified for this.

To check the validity date of this certificate, please call +371 67323246.

Further clarification regarding the scope of this certificate and the applicability of the system requirements may be obtained by consulting the organisation.

Certificate issued: **Riga, 21/10/2022**

Version: **1**

Certificate validity: **20/10/2025**

SIA „Bureau Veritas Latvia”
Member of the board



Iveta Lazdiņa